Staff Variance Report For March 18, 2015 Special Commission Meeting

- "A" category = staff recommendation is for approval with no equal alternatives because of noncompliance is not adverse.
- "B" category = staff recommendation is for approval with equal alternatives as stated by the proponent.
- "C" category = reserved, meaning staff believes Commission needs to discuss entirety.
- "D" category = recommendation is for denial.
- "I" category = incomplete (with permission of the Chairman).
- "NVR" category = no variance required.

NOTE: All staff recommendations presume code statements on the variances by the applicant are correct, unless otherwise noted. This means that all code statements become conditions of the variances and, if not true, the variances would be subject to Commission sanction. All LBO and LFO responses that they have received a copy of the application for variance are in order, unless otherwise noted.

NCAA Event Cooking Tents White River State Park – Indianapolis March Madness Music Festival,

The code requires a minimum distance of 10' between cooking tents with sidewalls or drops where cooking is performed in tents. Cooking and heating equipment shall not be located within 10' of exits or combustible materials. Outdoor cooking that produces sparks or grease laden vapors shall not be performed within 10' of a tent or membrane structure. The request is to have various groups of cooking tents placed throughout site, connecting to each other without separations. There will be (6) 20' x 20' cooking tents, used for the public, and two cooking tent 30' x 30' and for the crew and VIP's. Turner Broadcasting will comply with the commission's request for alternative public safety. The tents will be up for a limited amount of time and a temporary situation with limited physical space to meet the 10' requirement. Each tent will be supplied with a fire extinguisher. There will be over 100 public safety officers on site for this event.

Link to view event http://www.ncaa.com/marchmadness/musicfest/faq